



State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES

6 Hazen Drive, P.O. Box 95, Concord, NH 03302-0095
(603) 271-3503 FAX (603) 271-5171



August 8, 2002

K. Robert Bengtson
Mowglis School of the Open
PO Box 9
Hebron, NH 03241

LETTER OF DEFICIENCY #WSEB 02-88
CERTIFIED MAIL 7099 3400 0018 5776 3179

Subject: Hebron - Public Water System: Camp Mowglis Upper (EPA #1117060)

Dear Mr. Bengtson

The records of the Department of Environmental Services (DES) show that the Camp Mowglis Upper water system is classified as a public water system (PWS), as defined by RSA 485:1-a. A PWS is defined as any water system serving 15 or more services, or 25 or more people for 60 or more days per year. As such, the water system owner is required to submit samples to the State laboratory or a State-certified laboratory for coliform bacteria analysis in compliance with NH Administrative Rule Env-Ws 325.

DES records show that Standard Maximum Contaminant Level (MCL) violations for total coliform bacteria, as defined in NH Admin. Rule Env-Ws 315.01 have occurred and that letters of violation were issued for the following months:

June 2002 and July 2002

DES believes the MCL violations can be corrected and future violations prevented by taking the following actions:

- By August 22, 2002**, retain the services of a qualified water system consultant to address the system's water quality problems relative to the recent bacteriological occurrences; and
- 2 By September 10, 2002**, submit to DES for review a copy of the consultant's report including recommendations and an implementation schedule to correct the water system deficiencies.

Pursuant to Env-Ws 351, owners of public water systems are required to issue public notification when a system has exceeded the MCL limit for coliform bacteria. DES records show that the water system failed to perform public notification for the following month:

June 2002


In view of the public notice violation, DES believes the deficiency can be corrected, and future violations prevented, by taking the following actions:

1. **By August 22, 2002**, carry out public notice requirements for the June 2002 bacteria MCL violation; and
2. **By September 10, 2002**, provide proof of public notice to DES.

In the event compliance is not achieved within this period, DES may take further enforcement action, including issuing an order requiring the deficiencies be corrected, initiating an administrative fine proceeding and/or referring the matter to the NH Department of Justice for imposition of appropriate penalties.

Please contact Alan Leach by phone at (603) 271-2854 or by e-mail at aleach@des.state.nh.us, if you have any questions regarding this letter.

Sincerely,



Anthony P. Grunta, P.G., Administrator
Water Supply Engineering Bureau

cc: Gretchen Rule, DES Legal Unit
Board of Selectmen, Town of Hebron Health Officers
Wayne D. King, Owner's Representative
EPA, Region 1